






TANQUE	No. DURM. (POR LADO)	L (cm)	X (cm)	Y (cm)	Z (cm)
12.000 Gal	2	549	154	294	101
12.000 Gal Comp.	2	549	154	294	101
5.000 Gal	1	510	101	308	101
6.000 Gal	1	594	101	392	101
8.000 Gal	2	391	122	168	101
10.000 Gal	2	465	112	252	101
10.000 Gal Comp.	2	465	112	252	101
15.000 Gal (puntas)	3	465	112	252	101
15.000 Gal (centro)	3	428	109	210	109
15.000 Gal Comp. (2 puntas)	3	506,55	111,91	293,44	101,2
15.000 Gal Comp. (1 centro)	3	344,49	67,4	209,6	67,4

FLUID CONTAINMENT ANDINA				
APROBADO: J. HERNANDEZ	DURMIENTES DE CONCRETO PARA SISTEMA DE ANCLAJE DE TANQUES DE 8' DE DIAM.			
REVISADO: J.L. ROJAS				
Elaborado J.L. Rojas	ESCALA: S/E	FECHA 15/02/10	REVISION N° 00	PLANO N° FCA-DUR-0209